

PURCHASING DEPARTMENT

**TOWN OF ARLINGTON
730 Massachusetts Avenue
Arlington, MA 02476**

Telephone 781.316.3003
Fax 781.316.3019

July 3, 2023

SOLICITATION FOR QUOTES

#23-42 Fence Removal/Installation – Stratton Elementary School

ADDENDUM NO. 1

This addendum is to respond to questions submitted by potential responders.

Question 1: Will there be a public bid opening on July 6th?

Answer: No. Since this solicitation is a request for quotes, there will be no public bid opening.

Question 2: Is there a requirement for a bid bond?

Answer: No. Since this solicitation is a request for quotes, there is no requirement for a bid bond.

Question 3: Please specify the size of the terminal post.

Answer: 3"

Question 4: Please specify the size of the line post.

Answer: 2 1/2"

Question 5: Please specify the type of fabric.

Answer: The chain link is class 2b fuse bond black vinyl fabric.

Question 6: Please specify the size of top rail.

Answer: 1 5/8"

Question 7. Please specify the dimensions of the gates.

Answer: The gate height is 4'; the gate widths are specified in the scope of services.

All other terms and conditions of the solicitation and scope of services remain unchanged

**ADDENDUM MUST BE ACKNOWLEDGED ON THE QUOTATIONS FORM. FAILURE TO
ACKNOWLEDGE ANY OR ALL ADDENDA COULD RESULT IN REJECTION OF YOUR
QUOTE AS NON-RESPONSIVE.**

Sanford Pooler
Town Manager