



Engineering Division

TOWN OF ARLINGTON  
Department of Public Works  
51 Grove Street  
Arlington, Massachusetts 02476  
Office (781) 316-3320 Fax (781) 316-3281

June 17, 2024

**IFB #24-05: Wood Bridge Deck Replacement  
Minuteman Bike Path/Alewife Brook Bridge**

**Addendum No. 3**

The attention of Bidders submitting bids for the above-referenced project is called to the following Addendum to the Invitation for Bids. The items set forth herein, whether of omission, addition, substitution, or clarification, shall be included in and form a part of the proposal submitted and shall become part of the Contract.

The purpose of this addendum is to respond to final questions submitted by interested parties and to correct the date of the bid deadline erroneously issued in Addendum No. 2.

**1. Correction of Bid Deadline Extension:**

The bid deadline has been extended to **June 20, 2024, at 2:00 p.m.** The July 20 date published in Addendum No. 2 was a typographical error.

**2. Bidder Question Responses:**

- **Question:** Do you have a CCA retention for the lumber?
- **Answer:** The CCA Retention Level for the bridge decking shall be 0.40 (pcf) and is suitable for Ground/Fresh Water Contact

All other terms and conditions of the bid documents remain unchanged.

**ADDENDUM MUST BE ACKNOWLEDGED ON THE BID FORM. FAILURE TO ACKNOWLEDGE ANY OR ALL ADDENDA COULD RESULT IN REJECTION OF YOUR BID AS NON-RESPONSIVE.**

James Feeney  
Town Manager